

ADDENDUM No. 3

for

Rehabilitate a Portion of Taxiway 'A' & Taxiway 'F'
Bid # FY18-805-55

at the Manchester – Boston Regional Airport

Due to be opened 1:00 p.m., on August 27, 2018

Date: _____ **August 23, 2018** _____

The attention of firms submitting proposals for the work named above is called to the following modifications to the documents as were issued.

The items set forth herein, whether of clarification, omission, addition and/or substitution, shall be included and form a part of the Proposer's submitted materials and the corresponding contract when issued. No claim for additional compensation, due to lack of knowledge of the contents of this Addendum will be considered.

All Proposer's are advised that receipt of this notice and all attached material must be duly acknowledged in the space provided on the signature page of the proposal documents, and **by the insertion of this sheet, signed, and submitted with your Proposal package.**

This form must be signed and attached to the original copy of your submission.

The attached sheets contain information or clarifications requested or discussed.

Receipt of Addendum No. 3 to the REQUEST FOR PROPOSALS for **Rehabilitate a Portion of Taxiway 'A' & Taxiway 'F'** at the MANCHESTER-BOSTON REGIONAL AIRPORT is hereby acknowledged.

COMPANY NAME: _____

SIGNED BY: _____

NAME AND TITLE PRINTED: _____

TELEPHONE: _____ FAX: _____

CLARIFICATIONS

Addendum Item No.1 -

SUBMITTED QUESTION:

Pay Item L-125-1 Base Mounted L-850C RWY Edge Light: Please confirm the filter color requirement for this New Fixture? Do the details on Drawing E4.7 apply to this Pay Item?

CLARIFICATION:

The color filter requirement is White/White. Yes, the referenced detail applies to this pay item.

Addendum Item No.2 -

SUBMITTED QUESTION:

On Drawing E4.7, Detail A: Is the L-868 Base Can Top to be Class 1B?

CLARIFICATION:

All base can sections are to be of the same class. Per spec. section L-125-2.8, bases for in-pavement fixtures are to be Class 1B and bases for elevated fixtures are to be Class 1A.

Addendum Item No.3 -

SUBMITTED QUESTION:

I am inquiring about the process to allow ADS to bid our HP Storm Pipe as an alternate to the RCP drainage pipe on the above referenced project.

CLARIFICATION:

ADS HP Storm Pipe, or approved equal may be substituted for the 12" RCP called for under Item D-701-1.

END OF ADDENDUM #3